

STORAGE MIX TO ENHANCE RENEWABLE PENETRATION



January 2018

Table of contents

I

Moroccan renewable potential and electricity demand

II

Could electricity generation change its paradigm ?

III

Renewable mix to maximise renewable into grid

IV

Storage mix to enhance renewable penetration into energy mix (battery, hydro pumped, thermal and hydrogen)

V

Midelt Project: a case of solar power plant with thermal storage competitive with coal



Moroccan renewable potential and electricity demand



masen


endless power for progress

RENEWABLE ENERGIES, AT THE HEART OF MOROCCO'S ENERGY STRATEGY




Strong will of increasing renewable energy share within the national mix by 2020 and 2030, through a roadmap of deployment based on an optimal technological mix


2009



2020



2030



Renewable energy represented 28% of installed capacity



Renewable energy will represent 42% of installed capacity



Renewable energy will represent 52% of installed capacity

Morocco launched the NOOR Plan (the Moroccan solar plan), to be implemented by masen



Development of a minimum of 2 000 MW by 2020

Masen will implement a minimum of 6 000 MW of renewable energy by 2030

Conventional energy

Renewable energy

Projects developed/to be developed by masen

High renewable potential covering all regions

Hydraulic :

Potential in 6 regions even 2 regions Fès-Meknès and Béni Mellal-Khénifra concentrate main potential

CSP :

Best potential concentrated in the 4 eastern regions (saharien side of the Atlas)

Wind onshore :


9/12 regions have wind potential , the 2 southern regions Laayoune-Boujdour-Sakia El Hamra and Oued-Eddahab have the best potential

PV :


High potentiel all around the kingdom

Wind offshore:

Promising potential of floating wind on atlantic coast between Essaouira and Agadir



MOROCCAN ELECTRICITY DEMAND



Moroccan Load curve



Need storage to meet the Moroccan electricity demand especially peak demand



II. Could electricity generation change its paradigm ?




masep

endless power for progress

One century of conservatism : Could electricity generation change the paradigm ?




Conventional electrical generation:



A single model for all electrical systems

Controlled generation
Vs
Variable demand



Renewable intermittent generation is being forced in such system

>> It seems to be a great mistake <<




III. Renewable mix to maximise renewable into grid



masden


endless power for progress

III. Renewable mix to maximise renewable into grid



Mix renewable technologies to maximise useful energy






IV. Storage mix to enhance renewables penetration in energy mix




masden
endless power for progress

Storage mix to enhance renewable penetration into energy mix (role of battery, hydro pumped and thermal storage)




Storage mix to enhance renewable penetration into energy mix (role of battery, hydro pumped and thermal storage)

Hydro pumped storage



- + Mature energy storage
- + Hours
- + Lowest cost
- + Linked to potentiel site

Thermal storage



- + Limited maturity energy storage
- + Long time (many hours)
- + Used onsite

Batteries



- + Limited maturity in utility scale
- + Capacity storage
- + installation everywhere
- + High cost decreasing fast

Hydrogen



- + Limited maturity
- + High potentiel
- + High potentiel (power to X)
- High cost



A mix taking into account each need is necessary






**V. Midelt Project: a case of solar
power plant with thermal
storage competitive with coal**



masen

endless power for progress




1

Meet the midday peak load during summer using the PV technology (low LCOE).



2

Meet the evening Peak load using CSP technology thanks to thermal storage.
 PV could be used with heaters if feasible.




Moroccan Load curve




A hybrid PV/CSP solution should meet the Moroccan energy demand while reducing the LCOE

Analysis for PV with Storage Batteries solution



Price of batteries for utility scale applications for 2014*



Estimate of operational and planned battery storage (MW) in the power sector by country *

Different application of Batteries

Energy Batteries
for production during the peak hours

- High price
- Reduced lifetime
- Limited track record
- Could be more attractive for other market (Electric vehicles)

Capacity Batteries
for grid frequency stability support

- Developed by some countries (Japan, USA...) in the grid as support solution
- ONEE did not specify any requirement for the NOOR_M regarding the PV intermittence.
- If added, batteries could ameliorate the capacity during peak hours.

A maximum of 1 min allowed ramp-up (capacity variation) during day could be required






To be proposed to ONEE and adopted if needed

It will increase the CAPE by ~ 1.1% (based on 20MWh battery)

(*) Source :IRENA_BATTERY STORAGE FOR RENEWABLES: MARKET STATUS AND TECHNOLOGY OUTLOOK (January 2015)

Load curve of one Hybrid PV/CSP studied solution in Midelt VS NOOR Ouarzazate



Midelt load curve could be comparable with Ouarzazate Load curve

- Production of a typical hybrid power plant (Tower 150MW_7h and PV 262 MW_{DC}1 axis)
- NOORo Total production (Devlopper performance model for NOOR_o I, II and III and simulation results for NOOR_o IV)

TECHNICAL CONFIGURATION

Objective

- To produce Electricity during day using PV and/ or CSP (During the day, electricity may be produced exclusively from PV).
- To secure 5 hours peak production (CSP with storage).

Allotment

First phase: 2 Hybrid power plants



Requirements

Installed Capacity

- CSP gross capacity between **150MW and 190MW** per plant.
- DC/AC ratio shall be optimized by the Bidder to provide firm and linear curve during the day
 - ↳ The installed **PV_{DC} capacity to be optimized** by the Bidder.

Net Capacity (at ONEE busbar)

- At the Delivery Point, the net measured capacity during day could exceed the net measured capacity during night **by 20%**.
 - ↳ The maximum net measured capacity during the day will be between **180MW and 228MW**.

Storage

- **Minimum 5h of storage** to cover peak hours from CSP.
- Requirement to **maximize and to prioritize the storage from CSP before the peak hours**.


Ramp-up

- After startup and before shutdown, the **maximum allowed ramp up is ±10%** (of the maximum AC capacity during 1 min)
- Possibility to use batteries for ramping support.


Technologies

- CSP: **Tower or PT**
- PV : All mature technologies: **mc-si, c-si, thin film, CPV**

Typical Load curve (when the irradiation will be sufficient)



COMMON INFRASTRUCTURES AND CORRIDORS



Those proposed corridors may be changed according to the detailed feasibility study of each infrastructure

	Details
Land	4118 Ha
Drainage system with erosion protection	≈ 8 km
Security system	≈ 30 km
Firefighting protection system	--
Common Roads	≈ 30 km
Common Water system	≈ 14 km
Electricity	<ul style="list-style-type: none"> ▪ 225KV substation ▪ 400 kV power line operating at 225 kV
Telecommunication System	--
Complex Administration Building	--

NOOR Midelt: Site Layout



Midelt site areas :

- 1st parcel: ≈ 3153 ha
- 2nd parcel: ≈ 990 ha

Expected allotment:

- 4 Hybrid power plant areas
- 1 common facilities area



QUESTIONS