

Preliminary Results of the World Bank Low GWP Alternative Demonstration Project in Saudi Arabia

Karim Amrane, Ph.D.

President

KA Consulting Services, LLC

International Conference on Sustainable Cooling: *A high-level dialogue on challenges and opportunities, and 5th annual CO₃OL workshop*
28-30 November 2018, World Bank, Washington DC



KA Consulting Services, LLC

Montreal Protocol ExCom

UNITED
NATIONS

EP



United Nations
Environment
Programme

Distr.
GENERAL

UNEP/OzL.Pro/ExCom/76/46
15 April 2016

ORIGINAL: ENGLISH



EXECUTIVE COMMITTEE OF
THE MULTILATERAL FUND FOR THE
IMPLEMENTATION OF THE MONTREAL PROTOCOL
Seventy-sixth Meeting
Montreal, 9-13 May 2016

United Nation Environment Program

Saudi Arabia: Demonstration project at air conditioning manufacturers to develop window and packaged air conditioners using lower GWP refrigerants (World Bank)

The Executive Committee considered the proposed demonstration project as described in document **UNEP/OzL.Pro/ExCom/76/46.**



KA Consulting Services, LLC

PETRA KSA Facility

Petra's KSA facilities are in the King Abdullah Economic City in Rabigh - Saudi Arabia, with a total area of 45,000 m² (485,000 ft²), employing more than 450 persons in the fields of manufacturing, research and development, management, design, technical support, sales, marketing and after sales services.



Scope of Work

- Petra asked to design, develop, and test air-cooled packaged chillers
 - Alternative Refrigerants
 - HFC-32, GWP= 675, safety classification A2L
 - HC-290 (propane), GWP<4, safety classification A3
 - Baseline refrigerant: R410A, GWP=2088, safety classification A1
 - 3 cooling capacities: 40kW, 70kW, and 100kW
 - Total number of chillers built: 6
 - Total number of chillers tested: 9 (R410A as a drop in)



Refrigerant Safety Classification

		SAFETY GROUP	
F L A M M A B I L I T Y	Higher Flammability	A3	B3
	Lower Flammability	A2 A2L*	B2 B2L*
	No Flame Propagation	A1	B1
		Lower Toxicity	Higher Toxicity
		INCREASING TOXICITY	

* A2L and B2L are lower flammability refrigerants with a maximum burning velocity of ≤ 10 cm/s (3.9 in./s).

A2L safety group classification used by several refrigerant designation standards:

- ASHRAE Standard 34
- ISO 817

Figure 1 Refrigerant safety group classification.

from: ASHRAE Standard 34-2010



Project Design – Charge Limitation

- Followed procedures outlined in ISO 5149-2014
 - Authorized occupancy “C” (i.e. manufacturing facility)
 - Location classification “III” – Refrigerant containing parts are located outdoor
- Conclusion: No charge restriction for A2L and A3 refrigerants



Project Software Development

- New software was developed to simulate the performance of the units using the R290 and R32

AIR TO WATER SELECTION

Project Name: _____ Date: 02/07/2018 Country: Afghanistan
Unit Ref.: _____ Qty: _____ Rev: 0 Petra Offer Ref.: _____
Standard Custom Condenser Coils: Micro Channel Residential Water Chiller
Power Supply: 380/3ph/50Hz Refrigerant: R290 Chiller Type: PSC2H Model: PSC2H-40 Actual Name: _____
SELECTION Client And Specified Data General Data Sound Data Models Layout Load Distribution Standard Features Accessories

Unit Of Measure: Metric Elevation: 0 m Ambient: 35 °C

COMPRESSORS
No. 1
Type: SCROLL COPELAND
Hp: 15

COOLERS
Type: BRAZED PLATE
Model: CBS2X-80
Water In: 12.2 °C
Water Out: 6.7 °C

CONDENSERS
No. 1
Fins/inch: 12 Rows Deep: 4
Condenser Length: 1778 mm
Condenser Width: 889 mm
Select Fan Air Flow Rate

FANS
Euro Fans

No	Diameter	RPM
1	630	930
2	450	1400
3	800	900
4	900	930




No. of Fans: 3
Fan No.: 2
Diameter: 450
RPM: 1400
Running RPM: 0

OUTPUT DATA
COOLER
Water Flow Rate: _____ L/s
Water Pressure drop: _____ kpa
Minimum Loop Volume: _____ L
Minimum Flow Rate: _____ L/s
Water In Diameter: 1 [25] inch [mm]
Water Out Diameter: 1 [25] inch [mm]
CONDENSER SIDE
Condensing Temp.: _____ °C
Total Area: _____ m²
Total Air Flow Rate: _____ L/s
Calculated Velocity: _____ m/s
Total Capacity: _____ kW
Comp Power Input: _____ kW
Suction Temp.: _____ °C
EER: _____
COP: _____
IPLV-EER: _____ IPLV-kW/Ton: _____

<< Rate >>



Prototype Unit




Safety Considerations

- Eliminate all junction boxes inside the unit
- R290 leak detector beside refrigeration pipes
- Installing electrical enclosure in location far from welding pipes.
- Unit Marking – Compliance with IEC 60335-2-40



Safety Considerations

- Wire mesh added to the condenser coil for hot surfaces protection
- Increased number of isolation valves
- NEMA 4X electrical panel
- Airflow switch installed to ensure panel is always at positive pressure




Liquid Solenoid Valve




Ball Valve



Performance Comparison at Standard Ambient Condition



Performance Comparison at High Ambient Condition



Cost Analysis - Refrigerants

Comparing R290 and R410A

Unit	Refrigerant Charge R410A (KG)	Refrigerant Charge R290 (KG)	Charge Ratio	Cost of refrigerant R410A (\$)	Cost of refrigerant R290 (\$)	Cost increase (%)
PSC2H-100	16	11	1.45	104.8	134.75	28.6%
PSC2H-70	12	8	1.5	78.6	98	24.7%
PSC2H-40	6.5	5	1.3	42.575	61.25	43.9%

Comparing R32 and R410A

Unit	Refrigerant Charge R410A (KG)	Refrigerant Charge R32 (KG)	Charge Ratio	Cost of refrigerant R410A (\$)	Cost of refrigerant R32 (\$)	Cost increase (%)
PSC3H-100	16	12	1.33	104.8	225.36	143.66%
PSC3H-70	12	9	1.33	78.6	169.02	115%
PSC3H-40	6.5	5.5	1.18	42.575	103.29	142.6%



Cost Analysis – Major Components

PSC 100 Major Components Cost \$	R410A	R32	R290	R290 Unit with ATEX components
Compressor (2)	1821 Hermetic Scroll	1821 Hermetic Scroll	6286 Semi Hermetic Reciprocating	10686 Semi Hermetic Reciprocating
Condenser Coil	2560	2560	2560	2560
Evaporator Heat Exchanger	1829	1829	1829	1829
Expansion valves	123	123	196	196
Electrical Panel and cables	2054	4414	4414	13242
Piping	693	640	693	693
Pressure Relief Valve	275	275	246	246
Filter Drier	275	275	275	275
Solenoid valve	156	156	156	467
TOTAL (\$)	9786	12093	16655	30194
Percentage	0%	23.6%	70.2%	208.5%



Summary

- Air-cooled chillers were successfully built and tested with low GWP refrigerants R32 and R290
- International safety standards were followed and equipment was designed to reduce risk of using flammable refrigerants
- Performance is comparable or better than baseline refrigerant R410A at standard and high ambient testing conditions
- Cost of equipment slightly higher for R32 but significantly higher for R290
- Cost of components are expected to decrease as production increases



Thank you for your attention!



KA Consulting Services, LLC